



See-Berufsgenossenschaft
Prüf- und Zertifizierungsstelle
im BG-PRÜFZERT

European notified body
Identification number 0736

EC-Type Examination (Module B) Certificate

Certificate-No. **200.158**

Name and address of the manufacturer: **Feuerschutz Emil Jockel
Jägerwald 28- 30, D- 42897 Remscheid**

Date of issue: **16.12.2004**

Annex A.1 Item No & Item designation: **A.1/3.2 - Portable fire extinguishers**

Product designation: **"JOCKEL" DIN EN 3 fire extinguisher - 12 kg ABC - powder**

Product Type: **JOCKEL - P 12 J**

Intended purpose: **Portable fire extinguisher complying with SOLAS 74/88 Chapter II-2 Regulation 10.3, as ammended, IMO Resolution A.602 (15), IMO Resolution MSC. 97(73) 7.7.4, 7.8.4.1.3 und 7.17.3.7 (2000 HSC-Code), IMO Resolution MSC.98 (73) Chapter 4.1, 4.2 (FSS-Code).
Fire classes as per DIN EN 2 : A - B - C
Temperature range of function : from -30°C to +60 °C**

Testing based on (Specific standard): **EN 3-1 (1996), EN 3-2 (1996), EN 3-3 (1994), EN 3-4 (1996), EN 3-5 (1996) + AC (1997), EN 3-6 (1995) + A1: (1999)**

Remarks: **see overleaf**

The type tested was found to be in compliance with the Fire protection requirements of Marine Equipment Directive (MED) 96/98/EC as amended by Directive 2002/75/EC subject to any conditions in the schedule (part of this certificate).

This certificate may only be used in connection with module(s) **D, E or F** of this directive.

Expiry date: **31.01.2010**



Signature (Bork)

The approval of the installed equipment will be in force beyond the validity date until it is revoked!

Note 1: This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.

Note 2: Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply.

Note 3: The Mark of Conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-control phase module (D, E, or F) of ANNEX B of the Directive is fully complied with and controlled by a written inspection agreement with a notified body.



xxxx/yy

Note 4: "Wheelmark" Format

YY Last two digits of year mark affixed.

XXXX Notified Body number undertaking surveillance module



Postal address:
Postfach 11 04 89
20404 Hamburg

Office:
Reimerstwiete 2
20457 Hamburg

Tel: 0 40/3 61 37-0
Fax: 0 40/3 61 37 2 04
In any case, the German original shall prevail.